



Indo Petro Chemical

Electronic City, Bengaluru, Karnataka

Sr No	Characteristics	Unit	Test Method	Guaranteed Data	
				Min	Max
1	Appearance		Representative sample of the oil shall be examined in transmitted light under a thickness of 10 cm at ambient temperature	Clear free from sediment and suspended matter	
2	Density at 20 ° C	kg / dm ³	ISO 3675	0.895	
3	Kinematic Viscosity at 40 ° C at - 15 ° C	mm ² / sec	ISO 3104	16.5 800	
4	Flash Point, PMCC	° C	ISO 2719	140	
5	Pour Point	° C	ISO 3016	- 30	
6	Inter Facial Tension at 25 ° C	N / m	ISO 6275	0.04	
7	Neutralization Value	mg KOH/ gm	7.7 of IEC 296	0.03	
8	Water Content , Bulk / Drum	ppm	IEC 733	30 / 40	
9	Breakdown Voltage As Delivered / After Treatment	kV	IEC 156	30 / 50	
10	Dielectric Dissipation Factor (Tan δ)at 90 ° C & 40 to 60 Hz		IEC 247	0.005	
11	Corrosive Sulphur Copper Strip, 140 ° C, 19 Hrs		ISO 5662	Non Corrosive	
12	Anti Oxidant Additives	%	IEC 666	Not Detectable	
13	Oxidation Stability at 100 ° C, 164 Hrs		IEC 74		
	Neutralization Value	mg KOH /gm		0.4	
	Sludge	%		0.1	